


- NOTES:
1. FOR FIRE ALARM ON THE ROOF, SEE POWER PLANS E170-E172. ALL DUCT MOUNTED SMOKE SENSORS ARE PROVIDED BY E.C. AND INSTALLED BY MECHANICAL CONTRACTOR. WIRING IS BY E.C., I.E.C. RUNNING INDICATOR LIGHTS.
  2. E.C. SHALL COMPONENT, ALL LOCATION AND QUANTITIES OF SPRINKLER EQUIPMENT PRIOR TO FINISHES AND INSTALLATION OF ASSOCIATED FIRE ALARM COMPONENTS.

3RD FLOOR SECTION "A"  
SCALE: 7/8"=1'-0"

 <p>Building Key:</p>	<p>THIS MATERIAL IS CONFIDENTIAL AND MAY NOT BE DISCLOSED OR REPRODUCED WITHOUT THE WRITTEN CONSENT OF EGA ARCHITECTS © COPYRIGHT 2007 EGA</p>	<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Issued For:</th> <th>Date:</th> </tr> </thead> <tbody> <tr> <td>Design Develop.</td> <td>7-02-07</td> </tr> <tr> <td>50% CD Set</td> <td>8-13-07</td> </tr> <tr> <td>100% CD Set</td> <td>10-01-07</td> </tr> <tr> <td>Final Revs.</td> <td>11-19-08</td> </tr> <tr> <td>Code Revisions</td> <td>11-19-08</td> </tr> <tr> <td>Fire Alarm Revs.</td> <td>2-20-09</td> </tr> <tr> <td>Lighting Revs.</td> <td>3-10-10</td> </tr> <tr> <td>Exit Sign Revs.</td> <td>6-23-10</td> </tr> </tbody> </table>	Issued For:	Date:	Design Develop.	7-02-07	50% CD Set	8-13-07	100% CD Set	10-01-07	Final Revs.	11-19-08	Code Revisions	11-19-08	Fire Alarm Revs.	2-20-09	Lighting Revs.	3-10-10	Exit Sign Revs.	6-23-10	<h2 style="margin: 0;">THE GROVES in LINCOLN</h2> <h3 style="margin: 0;">CONGREGATE BUILDING</h3> <h3 style="margin: 0;">LINCOLN, MA</h3>	<p>CIVIL ENGINEER -RIZZO ASSOCIATES, INC. STRUCTURAL ENGINEER -SHELLEY ENGINEERING, INC. MEP ENGINEER -BLW ENGINEERS, INC. INTERIOR DESIGNER -WELLESLEY DESIGN CONSULTANTS</p>	<p><b>EGA</b> ARCHITECTS</p> <p>© 2007 EGA P.C.</p> <p>12 Auburn Street, 01900 North Attleboro, MA 978-462-5515 Fax: 978-462-5555</p> <p>528 Walnut Street Dix Notable, Lynn 01906 515-243-1800 Fax: 515-262-8880</p>
Issued For:	Date:																						
Design Develop.	7-02-07																						
50% CD Set	8-13-07																						
100% CD Set	10-01-07																						
Final Revs.	11-19-08																						
Code Revisions	11-19-08																						
Fire Alarm Revs.	2-20-09																						
Lighting Revs.	3-10-10																						
Exit Sign Revs.	6-23-10																						
<p>Sheet Title: <b>ELECTRICAL LEVEL THREE FIRE ALARM PLAN</b></p> <p>Sheet Number: <b>EM-15.0</b></p>																							